




# APPENDIX A - Register of Confined Spaces

Property: Good Sheds, 701 Collins Street, Melbourne, Victoria  
 Completed by: Jacqui Gould and Madeleine Parris  
 Date: 7<sup>th</sup> July 2015  
 Last Updated: 7<sup>th</sup> July 2015

Space ID	Type of Confined Space	Location	Security of Access / Type of cover	CONFINED SPACE CRITERIA						Photo
				A designed or intended primary to be occupied by a person?	B Is the space designed or intended to be at normal atmospheric pressure while any person is in the space?	D Does the space present a risk from:				
						An atmosphere that does not have a safe oxygen level?	Contaminants (including airborne gases, vapours or dusts) that may cause injury from fire or explosion?	Harmful concentrations of airborne contaminants?	Flooding/engulfment	
WT-01	Grey water tank	Ground level, adjacent staff kitchen	Locked door, secured manhole	✓	✓	✓	-	-	✓	
WT-02	Grey water tank	Ground level, adjacent staff kitchen	Locked door, secured manhole	✓	✓	✓	-	-	✓	
GT-01	Grease Trap	Ground level, external off Bourke Street	Locked door, secured cover	✓	✓	✓	✓	✓	✓	

APPENDIX A - Register of Confined Spaces

Space ID	Type of Confined Space	Location	Security of Access / Type of cover	CONFINED SPACE CRITERIA						Photo
				A	B	D				
				Is the space designed or intended to be at normal atmospheric pressure while any person is in the space?	Does the space present a risk from:	An atmosphere that does not have a safe oxygen level?	Contaminants (including airborne gases, vapours or dusts) that may cause injury from fire or explosion?	Harmful concentrations of airborne contaminants?	Flooding/engulfment	
GT-02	Grease Trap	Ground level, cleaners room	Locked door, secured cover	✓	✓	✓	✓	✓	✓	