

CERTIFICATE OF INSPECTION

AS/NZS ISO 22846.2-2020 – Industrial Rope Access Systems | **AS/NZS 1891 Series** – Industrial Fall-arrest Systems and Devices

SITE DETAILS			
Client Name:	Collins Square Management		
Client Contact:	Louise Luu		
Site Name:	Tower 5		
Site Address:	Collins St, Docklands, Victoria 3008		
Inspection Date:	09/02/2023	Certificate Expiry:	09/02/2024

SYSTEM INFORMATION			
System Type:	<input checked="" type="checkbox"/> Fall Arrest <small>AS/NZS 1891.4</small>	<input type="checkbox"/> Industrial Rope Access <small>AS/NZS ISO 22846.2-2020</small>	<input type="checkbox"/> Access <small>AS/NZS 1657:2018</small>
System Purpose:	Roof Maintenance		

CERTIFIED COMPONENTS <small>The following components have been certified:</small>	FAILED COMPONENTS <small>The following components have failed this inspection:</small>
1 x Structure mount static line, 21kN (T5-SL1)	

COMMENTS
<p>This inspection has been conducted in accordance with the requirements stipulated by Victorian legislation and applicable Australian Standards.</p> <p>All components found to be compliant during this inspection have been fitted with updated certification labels. Failed components have been tagged out of service. For further information on individual components, refer to system inspection report.</p> <p>To remain compliant with Australian Standards, anchor points must be inspected by a height safety equipment inspector at intervals no greater than 12 months. Inspections must be documented. Installation and inspection documentation should be made readily available to all users of the system.</p>

INSPECTOR NAME	SIGNATURE	DATE
Will Trotter		09/02/2023

Britesafe

The Experts in Roof Safety



2023 Height Safety / Industrial Rope Access System Inspection Report

Collins Square | Tower 5

Table of Contents

Disclaimer 3

Confidentiality 3

Report Details 4

System Description 4

Summary of Results 5

Layout Plan 6

Rectification Scope / Suggested System Upgrades 8

Inspection and Test Methodology 9

Disclaimer

Britesafe believes the information contained within this report to be correct at the time of issue.

Britesafe was commissioned to undertake an inspection of height safety components at this site. This is not a comprehensive height safety audit and should not be relied upon as an exhaustive record of all possible height safety related risks or hazards that may exist or potential improvements that can be made.

Through inspection and/or testing, the Britesafe height safety inspector has undertaken to determine whether or not the existing system components, as installed, continue to be serviceable.

If the installed system has been found to be unsafe, the height safety inspector will provide, by way of this report, recommendations for amendments to the system to achieve compliance.

In the event that the system has a questionable background or insufficient evidence is available to prove that the system fit for use, a complete system reevaluation may be required. Such a reevaluation may necessitate engineering verification or replacement of existing system components.

Upon completion of this inspection, a certificate detailing the results shall be provided to the client. This certificate should be made readily available to users of the system.

Confidentiality

In order to maintain the integrity and credibility of the inspection process and to protect the parties involved, it is understood that Britesafe inspectors will not divulge to unauthorised persons any information obtained during this inspection unless legally obligated to do so.

Report Details

Site Name:	Collins Square Tower 5
Site Address:	Collins Square Collins Street, Docklands, Victoria 3008
Height Safety Equipment Inspector:	Will Trotter
Date of Inspection:	09/02/2023
Certification Expiry:	09/02/2024

All components listed in the following report have been inspected and tested in accordance with legal requirements. Each component has been inspected in conformance with the applicable Australian Standard(s) checked below.

- AS/NZS ISO 22846.2 - Industrial Rope Access Systems
- AS/NZS 1891 Series – Fall-arrest Systems and Devices

System Description

The system installed at this site is designed for roof maintenance purposes. The static line is bolted to balustrade structure.

System

ITEM	PASS / FAIL
Access to System	PASS
Access Between Roof Levels	PASS
System Layout	PASS
System Documentation	PENDING REVIEW
Parent Structure	PASS

Components

ITEM ID	TYPE	RATING	MANUFACTURER	PASS / FAIL
T5-SL1	Structure Mount Static Line	21kN	Sayfa	PASS



Installation Details

ITEM ID	SYSTEM INSTALLER	DATE OF INSTALLATION
T5-SL1	Unknown	Unknown

Summary of Results

System Summary			
Compliant Anchor Point Quantity	0	Non-Compliant Anchor Point Quantity	0
Compliant Static Line Quantity	1	Non-Compliant Static Line Quantity	0
Compliant Ladder Quantity	2	Non-Compliant Ladder Quantity	0
Details: <ul style="list-style-type: none">The system is fit for use by adequately trained and competent personnel.The static line has been re-certified for a further 12 months.			

Access Ladder Register

TYPE	LOCATION	MANUFACTURER	HEIGHT	PASS / FAIL
T5-L33-LD1				
Portable Ladder	BMU Platform	Sayfa	1500m	PASS AS/NZS 1657:2018
				
T5-L33-LD2				
Step Type Ladder	Plant Area	Sayfa	2900m	PASS AS/NZS 1657:2018
No further works required.				
				

Layout Plan

TOWER 5

PERMIT ID#	APPROVE PLAN#	START	1. SAFETY FENCE	FINISH # - (See 'Logistics on Roof Safety' in previous pages)
DESIGN ID#	SCALE LINE		WALKWAY	
PERMIT CH#	CLIENT#		ROOF ACCESS HATCH	
NITS	EXECUTIVE		NO ACCESS	1. PROTECTIVE NETTING

Verify all dimensions and the primary safety equipment used. Do not scale from this drawing. This drawing is copyright and remains the property of Britesafe and should be reproduced or copied without the written permission of Britesafe. Under 'Scale/Date' insert a 30' plus edge protection only. Symbols are defined in a full manual. Symbols suggest slight corners to make.

All components that have passed this inspection have been fitted with updated certification labels. These components have been deemed fit for use by trained and competent personnel.

A system information and certification sign has been installed at each roof access point.

Any failed components have been tagged out of service and are not to be used.

Rectification Scope / Suggested System Upgrades

Based on the results of the inspection, the following works are suggested:

- a. No further works are required.
-

Inspection and Test Methodology

Anchor Points

In accordance with Australian Standard 1891.4:2009 – Industrial fall-arrest systems and devices and AS/NZS ISO 22846.2 – Industrial rope access systems, permanently installed anchor points are to be inspected at intervals not exceeding 12 months. The anchorages are visually inspected for signs of deterioration, which might make them unserviceable, together with any other requirements contained in manufacturers' instructions. The parent structure is also visually inspected for modifications or deterioration which might lead to loss of anchor strength. Drilled-in, glued-in and friction anchors are proof loaded by application of an axial pull-out force of 50% of the anchor's design load.

Horizontal and Vertical Life Lines and Rails

In accordance with Australian Standard 1891.4:2009 – Industrial fall-arrest systems and devices, life lines of steel construction and rails are to be inspected by a height safety equipment inspector at intervals as recommendation by the manufacturer to a maximum of five-yearly. In the absence of such a recommendation, static lines are to be inspected on an annual basis. The inspection is carried out in accordance with the manufacturer's instructions. Line anchorage points and rail support anchorages are inspected as per the methodology for anchor points above. The parent structure is inspected for any modification or deterioration which might lead to a loss of anchorage strength. Cables terminations, line tensioners, fixings and other system components are inspected in accordance with AS1891.4 clause 9.3.5.

Important! Any system which has not been certified in over 12 months cannot be used. All inspections are to be documented. Upon completion of the annual testing regime, a certificate detailing the results of the inspection should be supplied to building management. This certificate and any installation documentation should be made readily available to users of the system.
